



# Water System Operations Manager's Report

Engineering and Operations Committee  
Item 7a  
April 11, 2011

# Current Operations

- Blends at Weymouth, Diemer, and Skinner plants are 45 percent State Project Water
- March demands of 82 TAF were about 32 TAF lower than March 2010
- Article 21 surplus SWP supplies are still available
- CRA is currently operating at 5 pumps

# Shutdowns

- Just completed a shutdown of Weymouth Plant and local treated water pipelines
- Calabasas Feeder is currently shutdown
  - Carbon Fiber repair of 7 pipe sections
  - Identified “broken back”
  - District forces currently making repairs with steel liners
  - Shutdown extended from April 10 to April 17

# Metropolitan Distribution System



# Monterey Valve



Unloading valve at site



Installing reducer piece

# Calabasas Feeder "Broken Back"



# Diamond Valley Lake

## Storage Levels



DVL: 93% of 810 TAF Maximum Storage

