



Water System Operations Manager's Report

Engineering and Operations Committee
Item 7a
September 10, 2012

Current Operations

- SWP blend targets are 20% at Weymouth, 40% at Diemer, and 70% at Skinner
- August 2012 demands of 191 TAF were 19 TAF lower than August 2011
- The CRA is currently at a 7 pump flow
- Maximizing on-peak generation at Wadsworth Pumping Plant
- 2012 SWP Allocation remains at 65%

Annual Shutdown Plan

- Shutdown planning for the 2012/13 season is near completion
 - Final schedule will be released to the Member Agencies later this month
 - There are 27 major shutdowns planned
- Key shutdowns include:
 - Colorado River Aqueduct
 - Upper Feeder (Treated) and Weymouth Plant
 - PCCP Repairs on six major feeders
- Staff will provide progress updates

Diamond Valley Lake

Storage Levels



DVL: 92% of 810 TAF Maximum Storage

