



Water System Operations Manager's Report

Engineering and Operations Committee
Item 7a
October 8, 2012

Current Operations

- SWP blend targets are 20% at Weymouth, 40% at Diemer, and 70% at Skinner
- September 2012 demands of 179 TAF were 18 TAF lower than September 2011
- The CRA is currently at a 1 pump flow
- 2012 SWP Allocation remains at 65%
- Agencies have ordered about 35 TAF of full service water for groundwater replenishment



From Inland Feeder



From DVL



144" Butterfly Valve

Wadsworth Plant

To San Diego Canal





3/4-inch gap

Existing 144" Diameter Coupling

1/2-inch gap

Rolling Butt Strap



Diamond Valley Lake

Storage Levels



DVL: 90% of 810 TAF Maximum Storage

Central Arizona Project - Canal Breach



Central Arizona Project - Canal Breach



