



Water System Operations Manager's Report

Engineering and Operations Committee

Item 7a

June 12, 2017

Current Operational Conditions

- 2017 SWP Allocation is 85%
- SWP blend targets are 75% at Weymouth, Diemer, Skinner
- The CRA is currently at a 4 pump flow
- May 2017 deliveries of 113 TAF were 26 TAF lower than May 2016
- Continuing to fill storage based on WSDM principles

Weymouth ORP Start-up

- Notice of completion issued to construction contractor
- 14-day test initiated on May 31
- 42-day test scheduled for mid June
- Online date for regulatory compliance – early Fall



