



Engineering Services Manager's Report

Engineering and Operations Committee
Item 7b

November 13, 2017

Strategy for Incorporating Seismic Resilience Into Capital Projects

- Continue to conduct seismic assessments & perform upgrades of structures & facilities
- Maintain capability to recover & perform repairs quickly after seismic events
- Incorporate seismic resilience into new pipeline projects
- Evaluate results of vulnerability assessments of exist. distribution system (pipelines, tunnels, canals)
 - Identify mitigation measures & prioritize
 - Execute high-priority projects
 - Relatively few projects are anticipated to proceed based on seismic resilience as the primary driver
 - Mitigate most seismic hazards via long-term rehab programs
 - Every project is an opportunity to make significant improvements over time

Status of Seismic Assessments & Upgrades of Individual Facilities



Pre-1990 Above-Ground Structures

311

Rapid Evaluations

311
Done

0
Remain

Rapid Evaluation Results

195 OK

116 Potentially
Deficient

Seismic Upgrades

56
Upgraded

30 in Design
or Const.

2 Detailed
Evaluations
Underway


28 Planned for
Detailed Eval.

Detailed Evaluation Priority

4 Related
to Water
Delivery

24 Not
for Water
Delivery

Examples of Projects That Incorporate Seismic Resilience




1. Second Lower Feeder

- Project underway to rehabilitate 28 miles of 78-inch dia. PCCP under multiple const. contracts
 - Majority of work includes lining PCCP with steel liner
 - Internal pressure is 300 psi
- Newport-Inglewood Fault
 - Capable of producing M7.5 earthquake
 - Potential horiz. displacement up to 16 ft at fault crossing, along with liquefaction
- Planned solution
 - Replace exist. line at fault crossing with earthquake-resistant steel pipe

1. Second Lower Feeder

Fault Crossing – Newport-Inglewood Fault



2. Casa Loma Siphon

- Project underway for permanent repairs to leaks on 150-inch dia. Casa Loma Siphon No.1 on the CRA
 - Regional subsidence has caused leaks for decades
 - Siphon No. 1 was originally concrete pipe, now steel pipe with external sleeve-type couplings on every joint
 - Couplings are corroded & continue to leak
 - Internal seals installed recently as interim measure
 - Internal pressure is 21 psi
- Casa Loma Fault (San Jacinto Fault System)
 - Capable of producing M6.7 earthquake
 - Potential displacement of 1 ft if fault ruptures on its own, or 10 ft if multiple reaches rupture
- Planned solution
 - Replace exist. line at fault crossing with earthquake-resistant ductile iron pipe

2. Casa Loma Siphon

Fault Crossing – Casa Loma Fault (San Jacinto Fault System)



