


CRA 230kV Transmission Relay Coordination System

Engineering and Operations Committee Item 7-3 May 13, 2019

Current Action

Authorize agreement with Southern California Edison in an amount not to exceed \$421,932 to implement a relay coordination system on the Eagle Mountain-Iron Mountain 230 kV transmission line to improve the reliability of the Colorado River Aqueduct 230 kV transmission system

CRA 230kV Electric Transmission System




Background

National Electric Reliability Corporation (NERC) standards require high-voltage electric systems to stabilize following a fault on the system

- Under more stringent NERC standards, there is potential for system instability in event of a fault on the Eagle Mountain – Iron Mountain transmission line
- Upgrades to Metropolitan and Southern California Edison (SCE) equipment needed to ensure compliance with NERC standards and maintain reliability of CRA 230kV system

Eagle Mountain – Iron Mountain 230kV Relay Coordination System





E&O Committee

May 13, 2019

Scope of Work

- Metropolitan and SCE will jointly implement the Eagle Mtn – Iron Mtn relay coordination system
 - SCE scope includes design and installation of communications equipment on SCE's CB 407 at Eagle Mtn PP
 - Metropolitan scope includes installation of communications equipment on CB 307 at Iron Mtn PP
 - Testing and commissioning of the system will be performed by both Metropolitan and SCE during the 2020 CRA shutdown

Agreement with SCE

- An agreement with SCE is needed for work associated with SCE equipment for the relay coordination system
- SCE agreement is for a not-to-exceed amount of \$421,923
- Board approval is required for new agreements exceeding \$250,000

Allocation of Budgeted Funds

Metropolitan Labor

Program mgmt. & contract admin.Met. Force ConstructionSubmittal review & record drwgs.

\$21,500 45,500 16,000

Contract - SCE

Remaining Budget

Total

421,932

20,068 \$525,000

E&O Committee

Project Schedule



E&O Committee

Item 7-3 Slide 9

May 13, 2019

Board Options

Option #1

Adopt the CEQA determination that the proposed action is not subject to CEQA

 Authorize an agreement with SCE for a not-to-exceed amount of \$421,932 to implement a relay coordination system on the Eagle Mountain-Iron Mountain 230kV transmission line

Option #2

Do not proceed with the project at this time

Staff Recommendations

Option #1

